

RWD NO. 4, DOUGLAS COUNTY, KANSAS

9H WATER MAIN SIZE, ROUTING, CONNECTION AND MATERIAL POLICY

1. REQUIREMENTS

- a. The size, routing and points of connection of the water main (or mains) and the material specification shall be determined by the District upon considering adequate service to prospective consumers and the possible or contemplated future extensions of the main.
- b. Water main extensions shall be of not less than 6-inch size. The size of the water main will be as determined by the District.
- c. In special cases, the District may consider mains smaller than 6-inch, such as for short cul-de-sacs or similar arrangements less than 250 feet long that cannot be looped.
- d. All cost will be borne by the Applicant regardless of facilities and main size.
- e. The terminus of the water main (or mains) to be installed shall provide for looping of mains whenever possible. All dead-end mains shall extend to the far side of the property or the last lot being served (unless a lesser distance is determined adequate by the District) and shall have a clean-out installed at the end.
- f. Construction Standards for material and installation procedures are on file at the District office at 1768 N. 700 Road, Baldwin City, KS 66006, and are available for purchase by the public and interested parties.

Approved: January 13, 2004

c:\Mydocuments\Bylaws&Policies\Policy9HWaterMainSize,Routing,connection&MaterialPolicy\2004